

Siderise CW-FS Firestop and CW-CB Cavity Barrier

Factory engineered stone wool passive fire solutions for compartmentation in curtain wall and architectural façade systems



Application

Siderise CW-FS perimeter barrier and fire stop systems offer an extensive range of solutions for fire stop, and acoustic barrier requirements in all curtain wall applications. The CW Systems also resist the passage of smoke and hot gases. CW systems may also be used in fire stop and cavity barrier applications in conjunction with weathertight façade systems such as precast concrete cladding and architectural cladding panels.

The primary function of the CW system is to maintain continuity of fire resistance by sealing the void between the compartment floors or walls and the external curtain wall both horizontally and vertically.

Apart from being simple and quick to install CW systems' unique product construction also provides the ability to accommodate movement for the life of the building.

CCPI assessed status

CW-FS Perimeter Barriers and Firestops for Curtain Walling products have been assessed under the CCPI scheme.

Assessment Number: 000800009/0925



Product Description

Siderise CW systems are manufactured using a unique method that provides resilient lateral compression. This facilitates installation, ensuring the requisite tight fit and enhancing the fire integrity of the product.

Throughout the range, the materials comprise a one-piece product with a pre-compressed non-combustible stone wool core. The products also have integral aluminium foil facings to provide an overall Class A1 rating (to EN 13501-1).

The systems can offer tested fire resistance options ranging from 30 mins to 3 hours (3 hours to EN 1364-4 only) and can accommodate void widths up to 600mm (600mm voids to EN 1366-4 only). In addition to providing an effective seal against the passage of smoke and fire, the products are also acoustically absorptive.

Standard Systems

The materials can be either supplied as pre-cut units to suit a specified void size or in sheet form for cutting on-site.

Standard sheet products are supplied 1200 x 1200 mm which may prove beneficial when the actual void size is not known or where it varies significantly. Please note that when ordered in sheet form, the requisite quantity of fixing brackets needs to be purchased separately.

Pre-cut strips are available in 1mm increments of width to suit the cavity size to provide a tight compressive fit within the void - Please see Tables 2-4 regarding fit type. Each pre-cut CW unit is supplied with appropriate fixing brackets as part of the system.

The standard fixing brackets are supplied in galvanized mild steel in a flat form for folding on-site. Brackets are also available in stainless steel.

All hole positions are to be drilled to suit the varying site conditions. Different size brackets are available according to the cavity size – please see Tables 2-4.

All fixing brackets are to be mechanically secured to the substructure with suitable non-combustible fixings.

Fire Performance

Reaction to fire

Siderise CW-FS perimeter barriers and fire stops have third-party certification with Intertek and are classified as A1 to EN 13501-1:2018. Please see Table 1 for further information.

Table 1: Reaction to Fire Performance

Properties	Value
Classification	A1 to EN 13501-1
Certificate No.	WHI-09/02-22-000001-03 (UK) WHI20-32944302 (US)
Thickness Range	50-175mm*
Substrates	Mechanically fixed to gypsum or any other A1 or A2-s1, d0 substrate
Joints	With or without joints

Resistance to fire

Siderise CW-FS systems have been tested to both EN 1364-4 and EN 1366-4. CW-FS perimeter barrier and fire stops - maintained integrity (E) and insulation (I) requirements as detailed in Tables 2-4. The tables summarise the void sizes, fire resistance performance, and provide Third-party certification details where applicable.

Siderise CW systems provide continuity of fire resistance across the void when aligned with fire-rated elements to maintain compartmentation.

EN 1364-4 testing is the primary route for compliance for testing firestops in horizontal orientation in combination with curtain wall facades. When testing to EN 1364-4 in combination with 'Type A' non-fire rated curtain walls it is necessary to protect the spandrel zone with Siderise CW-FB. 'Type A' is the most common type of curtain wall in the UK. Please see our public website for EN 1364-4 tested arrangements and standard details. The CW-FB does not have a product specific fire resistance performance however it facilitates the fire resistance performance of the CW-FS Firestop in the EN 1364-4 test arrangement.

There are specific configurations of the test that can be chosen depending on the primary element to be assessed. To understand these further, please refer to BS EN 1364-4:2014. In a very simplified explanation, configuration 2 is used to assess performance of the façade and incorporates flaming on the inside and outside of the façade with specific furnace pressures and temperatures; this configuration would be used by system manufacturers for specific data on the façade. Configuration 5 is used to assess the linear joint seal/firestop in application and focusses on the ability of containing the fire inside the compartment, utilising higher temperatures and pressures. All Siderise EN 1364-4 testing is carried out in accordance with configuration 5.

Whilst existing test data is unlikely to replicate specific project details, Siderise have tested to EN 1364-4 with a number of different curtain wall systems with CW-FB in both single and double-layer arrangements.

In combination, CW-FS and CW-FB can be used in curtain wall façade assemblies requiring enhanced fire resistance performance.

The product combination provides the following advantages in the test arrangement:

- Protection of mullions and transoms
- Enhances the performance of the covered area of curtain wall to enable the CW-FS Firestop to perform for the

required period of fire resistance

- CW-FB is used as part of the tested arrangements to EN 1364-4 to allow the CW-FS Firestop to be certified for both 120- and 180-minute integrity and insulation
- Market-leading performance

On this basis, and to reflect the tested arrangement, Siderise recommends that the CW-FB is applied to the curtain wall in line with the CW-FB Installation Instructions wherever the CW-FS Firestop is being used in a horizontal orientation to the rear of a curtain wall. However, in instances where the project does not intend to utilize the CW-FB, we suggest consulting with the Supervising Authorities to ensure they accept the proposed application.

EN 1364-4 testing has been undertaken on a curtain wall system incorporating CW-FS120 in accordance with EAD 350141-00-1106, including horizontal movement cycling to 500 times ($\pm 10\%$ of void width) pre-test (UL Test 4789510602-1, Oct 2021).

Following the route set out in the EAD for horizontal movement cycling pre-test followed by testing to EN 1364-4 is the most demanding and relevant way of assessing the performance of firestops for commercially available 'Type A' curtain walls.

CW-FS has also been tested in isolation to EN 1366-4 in both horizontal and vertical orientations.

Approved Document B (England & Wales)

Approved Document B for England & Wales (2019 edition) gives classification to EN 13501-2 as the primary route to compliance via EN 1364-4 testing for fire stops in curtain wall systems in a horizontal orientation.

EN 1366-4 testing is also available for Siderise CW in isolation of the curtain wall, where Siderise CW-FS is tested between two leaves of concrete. This standard is applicable to firestops tested for curtain wall applications in a vertical orientation. EN 1366-4 is also applicable for non-curtain wall applications in both horizontal and vertical orientations.

For any voids not covered by Tables 2-4, please contact technical.services@siderise.com for advice on these options.

Third-party Certification

CE Marking (Cert No. 2531-CPR-CX010200) has been achieved based on ETA 21/0297 in accordance with EAD 350141-00-1106, which can also be downloaded from our online technical resources.

Certifire certification (CF 563) has been achieved, based on proven fire performance, for horizontal applications to EN 1364-4 (Table 2), and horizontal and vertical applications to EN 1366-4 (Table 3 & 4).

'Certifire certification and any product label is only applicable to the specific scope and field of application as defined within the current and valid Certifire certificate number CF563. Any additional details, amendments or additions to the product, or any use outside the scope or field of application, outside of that stated within certificate number CF563 has not been reviewed or approved by Warringtonfire.'

IFC certification (IFCC 1763) has also been achieved, based on proven fire performance for horizontal and vertical applications to EN 1366-4 (Table 3 &4).

Intertek certification (WHI19-32944301) has also been achieved, based on proven fire performance for horizontal applications to EN 1364-4(Table 2).

For further details on all Third-party Certification, the certificates can be downloaded from our online technical resources or from the certification body.

Table 2: Fire Resistance to EN 1364-4 (Horizontal Orientation for Curtain Walls)

Product Ref.	Void Width (mm)	Thickness (mm)	Compression (min.)	Integrity (Mins)	Insulation (mins)	Product Length (mm)	Bracket Requirement	Third-party Certification
CW-FS120	20 - 50	120	+10%	120	120	1200	2no.B65/110 600mm centres	Certifire CF 563 Intertek WHI19032944301
CW-FS180	20 - 50	150	+10%	180	180	1200	2no.B65/110 600mm centres	Certifire CF 563 Intertek WHI19032944301
CW-FS120	51 - 150	120	+10%	120	120	1200	2no.B65/110 600mm centres	Certifire CF 563 Intertek WHI19032944301
CW-FS180	51 - 150	150	+10%	180	180	1200	2no.B65/110 600mm centres	Certifire CF 563 Intertek WHI19032944301
CW-FS120	151 - 250	120	+10%	120	120	1200	2no.B195 600mm centres	Certifire CF 563 Intertek WHI19032944301
CW-FS180	151 - 250	150	+10%	180	180	1200	2no.B195 600mm centres	Certifire CF 563 Intertek WHI19032944301

All fixing brackets are to be mechanically fixed to the structure. Please see the installation instructions.

Façade deflection should be taken into consideration with respect to installation compression, please see 'Movement Characteristics'.

Table 3: Fire Resistance to EN 1366-4 (Horizontal Orientation For Non-Curtain Wall Applications)

Product Ref	Void Width (mm)	Thickness (mm)	Compression (min.)	Integrity (Mins)	Insulation (mins)	Product Length (mm)	Bracket Requirement	Third-party Certification
CW-CB30	20 - 50	75	+10%	60	30	1200	None.	Certifire 'CF 563' & IFCC 1763
CW-FS60	20 - 50	90	+10%	90	60	1200	None.	Certifire 'CF 563' & IFCC 1763
CW-FS120	20 - 50	120	+10%	120	120	1200	None.	Certifire 'CF 563' & IFCC 1763
CW-CB30	51 - 150	75	+10%	60	30	1200	2no.B65/110 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-FS60	51 - 150	90	+10%	90	60	1200	2no.B65/110 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-FS120	51 - 150	120	+10%	120	120	1200	2no.B65/110 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-CB30	151 - 250	75	+10%	60	30	1200	2no.B195 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-FS60	151 - 250	90	+10%	90	60	1200	2no.B195 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-FS120	151 - 250	120	+10%	120	120	1200	2no.B195 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-CB30	251 - 300	75	+10%	60	30	1200	2no.B355 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-FS60	251 - 300	90	+10%	90	60	1200	2no.B355 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-FS120	251 - 300	120	+10%	120	120	1200	2no.B355 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-CB30	301 - 350	75	+10%	60	30	1200	2no.B355 600mm centres	IFCC 1763
CW-FS120	301 - 350	120	+10%	120	120	1200	2no.B355 600mm centres	IFCC 1763
CW-FS60-X	301 - 600	120	+20mm	60	60	1200	2no.B355 600mm centres	Certifire 'CF 563' & IFCC 1763

All fixing brackets are to be mechanically fixed to the structure. Please see the installation instructions.

Façade deflection should be taken into consideration with respect to installation compression, please see 'Movement Characteristics'.

Whilst the CW range has been tested in general accordance with EN 1366-4 in narrow void widths 20-50mm without mechanical fixings and brackets, we note that some supervising authorities may require a form of mechanical fixing. We recommend engaging with the project supervising authorities prior to installation to ensure all their requirements are met.

Table 4: Fire Resistance to EN 1366-4 (Vertical Orientation)*

Product Ref	Void Width (mm)	Thickness (mm)	Compression (min.)	Integrity (Mins)	Insulation (mins)	Product Length (mm)	Bracket Requirement	Third-party Certification
CW-CB30	20 - 50	75	+10%	90	30	1200	None.	Certifire 'CF 563' & IFCC 1763
CW-FS60	20 - 50	90	+10%	90	60	1200	None.	Certifire 'CF 563' & IFCC 1763
CW-FS120	20 - 50	120	+10%	120	120	1200	None.	Certifire 'CF 563' & IFCC 1763
CW-CB30	51 - 150	75	+10%	90	30	1200	2no.B65/110 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-FS60	51 - 150	90	+10%	90	60	1200	2no.B65/110 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-FS120	51 - 150	120	+10%	120	120	1200	2no.B65/110 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-CB30	151 - 240	75	+10%	90	30	1200	2no.B195 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-FS60	151 - 240	90	+10%	90	60	1200	2no.B195 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-FS120	151 - 240	120	+10%	120	120	1200	2no.B195 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-CB30	241 - 300	75	+10%	90	30	1200	2no.B355 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-FS60	241 - 300	90	+10%	90	60	1200	2no.B355 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-FS120	241 - 300	120	+10%	120	120	1200	2no.B355 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-CB30	301 - 450	75	+10%	90	30	1200	2no.B355 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-FS60	301 - 450	90	+10%	90	60	1200	2no.B355 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-FS120	301 - 450	120	+10%	120	120	1200	2no.B355 600mm centres	Certifire 'CF 563' & IFCC 1763
CW-FS60-X	451 - 600	120	+20mm	60	60	1200	2no.B355 600mm centres	Certifire 'CF 563' & IFCC 1763

* For vertical firestop applications to the end of a flexible wall (e.g. stud partitions), please consult technical.services@siderise.com for advice on appropriate product selection and application.

All fixing brackets are to be mechanically fixed to the structure. Please see the installation instructions.

Façade deflection should be taken into consideration with respect to installation compression, please see 'Movement Characteristics'.

Whilst the CW range has been tested in general accordance with EN 1366-4 in narrow void widths 20-50mm without mechanical fixings and brackets, we note that some supervising authorities may require a form of mechanical fixing. We recommend engaging with the project supervising authorities prior to installation to ensure all their requirements are met.

Acoustic Performance

Additionally, the CW-FS range of barriers are acoustically absorptive.

Furthermore, the foil facings and the additional sealing of joints with Siderise foil tape all serve to provide improved airtightness.

Sound reduction between floors

The installation of the CW systems within an external curtain wall cavity can increase the floor-to-floor attenuation.

The acoustic flanking performance of a curtain wall detail will depend on the specifics of the construction. When incorporated between mass lines that close the slab-edge void, such as the Siderise AB10 overlay and CVB/C-10 cavity barrier, the CW-FS range can provide an absorptive layer which can increase the overall acoustic performance of the detail.

Table 5 confirms the laboratory tested values for Weighted Sound Reduction Index (dB Rw) in accordance with BS EN ISO 140-3: 1995, BS 2750 Pt 3: 1995.

Table 5: CW Acoustic Performance - Weighted Sound Reduction Index

Product Type	Thickness (mm)	Rw (dB)
CW-CB30	75	21
CW-FS60	90	22
CW-FS120	120	25

Siderise offers a range of complementary acoustic mass overlay materials which can further enhance the overall acoustic performance of the construction.

The Siderise AB10 is a flexible acoustic membrane for use as a mass-barrier above Siderise CW-FS fire stops in curtain walls. Using this acoustic upgrade offers an improvement to the acoustic performance of the firestop. Incorporating

mass barriers such as the Siderise AB10 into slab-edge details can assist with controlling floor-to-floor sound transmission.

Siderise AB10 is quick to install and is suitable for use in all curtain walls. The product is thin, flexible, and is designed to accommodate façade movement, unlike traditional mass-barrier materials such as steel or plasterboard.

As the AB10 is sold as an acoustic upgrade for our CW-FS firestops, we have not tested its standalone performance. However, for the purposes of assessment by project acoustic consultants, the Weighted Sound Reduction index (dB Rw) of the mass barrier layer alone is presented below (Table 6).

Table 6: AB acoustic performance - Weighted Sound Reduction Index

Product Type	Product Surface Mass (kg/m ²)	Rw (dB)
AB10	10	28

Table 7: CW-FS, CW-AB and CVB/C acoustic performance

Product Type	21 - 30dB Rw	21 - 30dB Rw + Ctr	36 - 50dB Rw	36 - 50dB Rw + Ctr	50dB Rw	50dB Rw + Ctr
CW-FS60	23	21				
CW-FS120	25	23				
CW-FS120 +AB10 Overlay			37	32		
CW-FS120 + AB10 Overlay + CVB/C10 below					51	45
CW-FS120 + 2mm Steel Plate Overlay + CVB/C10/75 below					53	45

The table above illustrates typical acoustic performance of CW-FS, CW-AB and CVB/C products when used in an arrangement, please see our website for individual product information and standard details. Please note that the values presented in the above table refer to the standalone performance of Siderise products only. For full system performance requirements given as a $D_{nT,w}$ or $D_{n,f,w}$ value, Contact our façades technical team at technical.services@siderise.com for performance guidance.

Thermal Performance

Thermal conductivity: $\lambda = 0.038 \text{ W/m.K} \pm 5\%$ (tested foil to foil) to EN 12667: 2001

Technical Specification

Siderise Perimeter Barriers Fire stops for Curtain Walling and Weathertight Façade Systems

Table 8: Product Properties

Properties	Value
Form Supplied	Sheets : 1200mm x 1200mm (UK and EU); 1200mm x 1150mm (RoW); Thickness is denoted by the rating Pre-cut strips: 1200mm x (void width + compression) x thickness, please see tables 2-4
Colour	Solid, green-brown exposed edges with silver aluminium top and bottom facings
Finish	Aluminium Foil
Density	Nominal 75 kg/m ³
Thermal Conductivity	$\lambda = 0.038 \text{ W/m.K} \pm 5\%$ (tested foil to foil) to EN 12667: 2001
Void Width	20mm to 600mm Please see tables 2-4
Fungi Resistance	When tested to ASTM C1338-19 no fungal growth was observed after 28 days
Water Vapour Absorption	5% by weight to ASTM C1104-19 (with foil facing removed). This meets the standard specification for 'Mineral Fibre Blanket Thermal Insulation for Light Frame Construction and Manufactured Housing' ASTM C C665-17, clause 7.5
Reaction to fire	EN 13501-1 : Class 'A1'
Resistance to fire	30 to 180 minutes, please see tables 2-4

Table 9: Physical Characteristics

Properties	Value
Manufacturer and Product Name	Siderise CW-FS
Product Type	Perimeter Barriers and Firestops for Curtain Walling
Code/Model/Reference/SKU	CW-FS
Description	See 'Product Description' section
Application/Use	See 'Application' section
Material	See Material Data Sheet section 3
Weight	Precut strips - Max Carton Weight 30kg Full individual sheets from 8.3 +/- 0.1 kg to approx 13.7+/- 0.4 kg (75mm to 120mm thick respectively)
Finish / Colour	Solid, green-brown exposed edges with silver aluminium top and bottom facings
Packaging	Pre-cut strips packaged in cardboard cartons size
Pack Size	Pre-cut strips packaged in cardboard cartons size up to 1230mm x 610mm Full sheets packaged on pallets 1210mm x 1210mm
Unit of Measure	millimetre (mm)
Chemical properties / Safety data sheets	See Material Data Sheet section 3
Size / Dimensions (product & installation spatial requirement)	See Table 8 'Form Supplied'
Shelf Life	N/A Store in dry conditions and protect from mechanical damage.

Movement

Movement Characteristics-Curtain walling and external facade deflection

For curtain walling applications it is imperative that the installed firestop can function effectively with due regard to all designed movement serviceability limits.

Siderise recognises that curtain walling and cladding façade systems will deflect due to:

- Positive wind-load
- Negative wind-load
- Occupational live load

The above are covered by EN 13116:2001.

Typically, a project may stipulate that the curtain walling system may have the following allowable deflection limits:

Under the declared wind loads the maximum frontal deflection of the curtain walling framing members shall not exceed $L/200$ or 15mm, whichever is less; when measured between the points of support or anchorage to the building structure in compliance with EN 13116. [Extract from EN 13830]

For vertical applications where the façade deflection may be up to 15mm, we recommend that you calculate the design deflection of the external façade system in both positive and negative wind load situations. Then follow Tables 2 to 4 + the additional design deflection of the system if required. Additional material allowances should be included whenever façade deflection is anticipated beyond the product compression requirement. For example, with a maximum expected façade deflection of 15mm:

Void Width + 10% Compression + Facade Deflection

For 180mm void = 180mm + 18mm + 15mm = 213mm of CW-CB/ CW-FS

Where the required compression of the firestop is greater than 10%, we suggest trialing the installation on-site to ensure it can be installed, as feasibility will vary depending on the void width.

These factors may inevitably combine to preclude the suitability and therefore the use of certain other systems e.g. high-density material slab products.

However, the CW-FS fire stop systems are remarkably effective for their function within curtain walling as the unique material construction can accept the cyclical negative and positive wind and live loads imposed on the façade.

Environmental

Recyclability

The stone wool core is recyclable.

Third-party verified EPD

Siderise CW Perimeter Barriers and Firestops have an Environmental Product Declaration (HUB-1301) in accordance with EN 15804+A2 & ISO 14025 / ISO 21930. Please see [EPD](#) in Product Resources or [EPD Hub](#) for further information.

60 Year Design life

To confirm long-term durability, CW Perimeter Barriers and Firestops have been put through EOTA TR 024 'Type X' accelerated age testing. This is the harshest category which replicates exposure to rain, UV, high temperatures, and frost and thaw cycles.

When correctly installed in recommended applications, CW Perimeter Barriers and Firestops have an expected service lifespan of 60 years.

Additional Information Available

The following information is available upon request or via download from the website:

- Third-Party Certification
- Declaration of Performance
- Environmental Product Declaration
- Material Data Sheet
- Standard Details
- Installation Instructions
- Installation Video
- NBS Specification Clauses

Technical Support

For technical advice or support please contact: technical.services@siderise.com

For Installation Training or Site Inspections please contact: site.services@siderise.com

For technical advice or support in the Middle East, India or Asia Pacific contact: smetech@siderise.com

Context

The information in this datasheet is believed to be accurate at the date of publication. Siderise has a policy of continuous product improvement and reserves the right to alter or amend the specifications of products without prior notice. Siderise does not accept responsibility for the consequences of using the products described outside of the recommendations within this datasheet. Expert advice should be sought where there is any doubt about the correct specification or installation of Siderise products.

CW-FS_4_02_20250228_1737